We	HK Instruments Oy
	Keihästie 7, 40950 Muurame, Finland
	declare under our sole responsibility for the products:
Product family	Electronic differential pressure switch and transmitter
Products	DPI
	The products are available with several optional features. The optional feature names are added after the product name separated with a dash (e.g.

The products fulfil the requirements of the following directives:

2014/30/EU	Electromagnetic Compatibility (EMC).
2011/65/EU	Restriction of Hazardous Substances (RoHS2) Directive.
(EU) 2015/863	Commission Delegated Directive, amending Annex II to Directive 2011/65/EU.
2012/19/EU	Waste electrical and electronic equipment (WEEE).
2001/95/EC	General product safety.
2014/35/EU	Low Voltage Directive (LVD).

The products are in accordance with the following harmonised standards:

EN 61326-1:2013	Electrical equipment for measurement, control and laboratory use - EMC requirements - Part 1: General requirements
EN 61326-2-3:2013	Electrical equipment for measurement, control and laboratory use - EMC requirements - Part 2-3: Particular requirements - Test configuration, operational conditions and performance criteria for transducers with integrated or remote signal conditioning
Issue date	15.05.2023
Signed	Anselmi Immonen (22. toukokuuta 2023 10:04 GMT+3)
	HK Instruments Oy, Anselmi Immonen Managing director