UKCA Declaration of Conformity

We	HK Instruments Oy Keihästie 7, 40950 Muurame, Finland
Product family	declare under our sole responsibility for the products: CO_2 transmitters
Products	CDT2000
	The products are available with several optional features. The optional feature names are added after the product name separated with a dash (e.g. CDT2000-1R-D). This declaration covers all the product variants.

The products fulfil the requirements of the following regulations:

S.I. 2016 No. 1091	Electromagnetic compatibility regulations
S.I. 2012 No. 3032	The restriction of the use of certain hazardous substances in electrical and electronic equipment regulations
S.I. 2013 No. 3113	The waste electrical and electronic equipment regulations
S.I. 2005 No. 1803	The general product safety regulations
S.I. 2016 No. 1101	The electrical equipment (safety) regulations

The products are in accordance with the following harmonised standards:

EN 61326-1:2013	Electrical equipment for measurement, control and laboratory use - EMC requirements - Part 1: General requirements
EN 61326-2-3:2013	Electrical equipment for measurement, control and laboratory use - EMC requirements - Part 2-3: Particular requirements - Test configuration, operational conditions and performance criteria for transducers with integrated or remote signal conditioning
Issue date	15.05.2023
Signed	Aul 2 Anselmi Immonen (22. toukokuuta 2023 10:06 GMT+3)
	HK Instruments Oy, Anselmi Immonen
	Managing director

HK Instruments Oy | Keihästie 7, 40950 Muurame, Finland | tel. +358 14 337 2000 | info@hkinstruments.fi