

UKCA Declaration of Conformity

We

HK Instruments Oy

Keihästie 7, 40950 Muurame, Finland

declare under our sole responsibility for the products:

Product family

Humidity transmitters

Products

RHT Duct

The products are available with several optional features. The optional feature names are added after the product name separated with a dash (e.g. **RHT Duct-D**). This declaration covers all the product variants.

The products fulfil the requirements of the following regulations:

S.I. 2016 No. 1091	Electromagnetic compatibility regulations
S.I. 2012 No. 3032	The restriction of the use of certain hazardous substances in electrical and electronic equipment regulations
S.I. 2013 No. 3113	The waste electrical and electronic equipment regulations
S.I. 2005 No. 1803	The general product safety regulations

The products are in accordance with the following harmonised standards:

EN 61326-1:2013	Electrical equipment for measurement, control and laboratory use - EMC requirements - Part 1: General requirements
EN 61326-2-3:2013	Electrical equipment for measurement, control and laboratory use - EMC requirements - Part 2-3: Particular requirements - Test configuration, operational conditions and performance criteria for transducers with integrated or remote signal conditioning
CISPR 11:2015 + AMD1:2016 + AMD2:2019	Industrial, scientific and medical equipment - Radio-frequency disturbance characteristics - Limits and methods of measurement

Issue date

15.05.2023

Signed



Anselmi Immonen (31. toukokuuta 2023 08:53 ADT)

HK Instruments Oy, Anselmi Immonen
Managing director